



# Listuguj Mi'gmaq Government

Gespe'gewaq (The People of the Last Land)

## ADDENDUM No. 3 Construction of a Triplex May 22, 2026

1. like there are no details for the crawlspace, like lights, heaters, etc. Do you know more if there would be any installation or information if needed? What type and how many?  
**Yes, in the crawl space you will need to include 10-20BTUs per square foot, and 2 lights per unit protected by GFCI for outlets rated 120 Volts or less and should also have an Ingress Protection rating of at least IP65, indicating their resistance to dust and low-pressure water jets.**

2. Do you have the distance between the building and the Hydro Quebec pole for the underground installation? We know the depth on the last addendum but not the distance.

**The distance between the building and the hydro pole should be 4 meters away from the building.**

3. For civil on triplex, can the band do it? Or do I use my sub-contractor

**You will be required to use your own sub-contractor.**