

ACKNOWLEDGEMENT OF RECEIPT OF

**ADDENDUM No. 2**

New Water Treatment Plant and Reservoir Construction

Listuguj, QC.

Project No. 1901412.002

Please sign this sheet to indicate that your company has received this notice and return it by fax or e-mail to:

**Englobe Corp.**  
Moncton, N.B.  
Attention: Jinette McCormack  
FAX: (506) 857-2753  
E-mail: jinette.mccormack@englobecorp.com

Company Name: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

**Total number of pages (including cover): 3**

---

**1.1 ADDENDUM**

.1 The following changes to the specifications and drawings are to be incorporated in the Tender Documents.

.2 Specifications

.1 Section 01 00 01 - General Requirement

.1 Replace Paragraph 1.16.1:

.1 The Contractor will be required to adhere to the following construction sequence and the major milestones are to be included in their Schedule of Work.

ITEM	DESCRIPTION	MILESTONE DATE (completed by)
	Year 2022	
1	Award of Contract	March 29 <sup>th</sup> , 2022
2	Contractors initial schedule (submitted to Engineer)	April 1 <sup>st</sup> , 2022
3	Mobilization to the site	April 1 <sup>st</sup> , 2022
4	Environmental site control	April 1 <sup>st</sup> , 2022
5	Shop drawing submittals	April 15 <sup>th</sup> , 2022
6	Removal of preloading fill and stockpiling for backfill (installation of reservoir base pad)	April 27 <sup>th</sup> , 2022
7	Building Foundation	June 15 <sup>th</sup> , 2022
8	Building Structural and Architectural	July 13 <sup>th</sup> , 2022
9	Reservoir Concrete Work	August 3 <sup>rd</sup> , 2022
10	Installation of reservoir accessories	August 10 <sup>th</sup> , 2022
11	Reservoir testing and draining (1-week test)	August 24 <sup>th</sup> , 2022
12	Installation of watermain and sewerage piping between building and reservoir	September 7 <sup>th</sup> , 2022
13	Backfilling Reservoir	September 14 <sup>th</sup> , 2022
14	Mechanical process piping and building plumbing	October 12 <sup>th</sup> , 2022
15	Building electrical	October 26 <sup>th</sup> , 2022
16	Well house upgrades	November 4 <sup>th</sup> , 2022
17	SCADA & programming (communications)	November 18 <sup>th</sup> , 2022
18	Testing and commissioning of new system	November 30 <sup>th</sup> , 2022
	Summer 2023	
19	Decommissioning of existing system including all demolition	May 30 <sup>th</sup> , 2023
20	Final grading and landscaping	June 9 <sup>th</sup> , 2023
21	Cleanup and final demobilization	June 16 <sup>th</sup> , 2023

.2 Section 03 30 00 - Cast-In-Place Concrete.

.1 Add the following item 1.2.3.1.3:

.1 Cast-In-Place Concrete Structural Slab and Beams, Complete.

.2 Remove the following sentence from item 1.2.3.3:

.1 Any slips not received and signed by the Engineer or his representative at the time of delivery will not be included for payment.

.3 Add the following item: 1.2.3.4:

.1 The total unit quantity to be used for measurement and payment for each item will be based on theoretical values as calculated by the Engineer using dimensions from the contract documents. No addition or reduction in payment will be considered based on in place

measurements within construction tolerances as outlined in item 3.5, or unless directed by the Engineer. The theoretical values may only be adjusted by the Engineer if there are changes to the reservoir design.

- .3 Section 04 04 25 - Masonry Units
  - .1 See Paragraph 2.2.1.3: Colours:
    - .1 For bidding purposes, the masonry unit shall be in the medium brown range similar to *Sandstone* by Brampton brick.
- .4 Section 04 26 16 – Veneer Masonry:
  - .1 Add Paragraph 1.5.6 as follows:
    - .1 The subcontractor in the Bricklayer Trade does not have to follow the NB Apprenticeship and Occupational Certification Act, as long as they are registered with, and follow the provisions for ratio of apprentices to journeypersons required by the relevant masonry association in Quebec.
- .5 Section 08 13 52 - Sectional Overhead Doors:
  - .1 Delete Paragraph 2.2.5:
- .6 Section 20 05 01 - Common Work Result for Mechanical
  - .1 Remove the following item: 1.5 Responsibility
- .7 Section 22 05 19 - Meters, Gauges and Instruments
  - .1 Acceptable equivalent for 2.8 Chlorination System:
    - .1 Prominent chlorination system, including Dulco Flex Peristaltic chlorine feed pump.
- .3 Drawings
  - .1 1901412-2D-E03
    - .1 Delete wording for conductor between the FIRE PUMP CONTROLLER and 150 HP FIRE PUMP “3#3/0 MI” and replace with “3#2/0 MI”.

## 1.2 TENDER OPENING

- .1 The tender opening date **HAS CHANGED**. Tenders will be received electronically in PDF format via e-mail to [Jinette.McCormack@englobecorp.com](mailto:Jinette.McCormack@englobecorp.com) until **2:00p.m. AST / 1:00p.m. EST, Tuesday, March 22, 2022.**

**A SIGNED COPY OF THIS ADDENDUM MUST BE INCLUDED WITH THE TENDER SUBMISSION.**

Firm: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_

**END OF SECTION**